

TOWN of HIGHLANDS



Bear Mountain
Fort Montgomery
Highland Falls
West Point

Chartered December 3rd, 1872

254 Main Street
Highland Falls, NY 10928
(845) 446-3398-4280
Fax: (845) 446-4298

May 15, 2018

Dear Town of Highlands Water Customer:

Enclosed is a copy of the 2017 Water Quality Report and Certification Form done by the Village of Highland Falls. We purchase our water from the Village. This report suffices to the Town as well.

In addition to the tests performed by the Village of Highland Falls, the Town of Highlands also performs the following tests and the results are as follows:

Federal ID # 3530057

TABLE OF DETECTED CONTAMINANTS

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg./Max) (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT Or AL)	Likely source of Contamination
Total Trihalomethanes (TTHMs)	NO	2017	LRAA* = 62.25 Range = 30 to 82	Ug/l	N/A	MCL = 80	Byproduct of drinking water disinfection needed to kill harmful organisms.
Five Haloacetic Acids (HAA5)	NO	2017	LRAA* = 15.075 Range = 9.5 to 20.7	Ug/l	N/A	MCL = 60	

*LRAA (Locational Running Annual Average) – indicates the average of the quarterly samples collected during 2016.

The Town of Highlands has its own dedicated phone line that will help serve your needs better. For daily operation please call (845) 859-4421, for emergencies (845) 446-4112 and for billing (845) 446-4280 X314.

Respectfully,

James Patterson
Designated Operator